



2017 Water Quality Report Uwchlan Division, PWSID# PA1150035

*Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo ó hable con alguien que lo entienda bien.*

About Your Drinking Water

Aqua Pennsylvania, Inc. (Aqua) is pleased to provide you with important information about your drinking water in this 2017 Consumer Confidence Report for the Uwchlan Division (public water supply ID- PA1150035). The report summarizes the quality of water Aqua Pennsylvania provided in 2017 - including details about water sources, what the water at your tap contains, and how it compares to standards set by regulatory agencies. Although the report lists only those regulated substances that were detected in your water, we test for more than what is reported. This report is only a summary of our testing during 2017. If you have any questions about the information in this report, please call 610.645.4248 or visit our website at AquaAmerica.com.

Sources of Supply

Water for the Uwchlan Division comes from ground and surface water sources. Ten wells at six well stations account for approximately 72 percent of the water supplied to Uwchlan Division. The Uwchlan Division is integrated with Aqua Pennsylvania's Main Division (PWSID# PA1460073), and some customers may receive a blended supply from the Main Division that comes from other wells, the Pickering and Perkiomen creeks and the Schuylkill River. The Main Division's water quality report is available from Aqua Pennsylvania on our web site listed above or a copy can be requested by calling the phone number above. Source Water Assessments by the Pennsylvania Department of Environmental Protection (DEP) were completed in 2004 for the Uwchlan Division wells. Source Water Assessments were completed in 2002 for the Pickering and Perkiomen creeks and the Schuylkill River. The sources overall have a moderate risk of significant contamination. Information on the source water assessment is available on the DEP website at www.depweb.state.pa.us (DEP keyword "Source Water Assessment Summary Reports"). Complete reports were distributed to municipalities, water suppliers, local planning agencies, and DEP offices. Copies of the complete report are available for review at the DEP Southeast Regional Office, Records Management Unit, 484.250.5900.

The sources of drinking water (tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organics, are byproducts of industrial processes and petroleum production and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. Radon is not regulated in drinking water. It is a radioactive gas that you cannot see, taste or smell. Most radon enters homes directly from underground. Radon can also be released into air from tap water. Generally, tap water is a small source of radon in indoor air.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline at 800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800.426.4791).

The following table lists contaminants that were detected in your water system. The table provides the average of the sources used to supply the Division as well as minimum and maximum observed levels of regulated contaminants.

Aqua Pennsylvania, Inc., Uwchlan Division, PWSID# PA1150035

Contaminants	Average Detection	Range of Detections	MCL	MCLG	Sample Date	Violation Y/N	Major Sources in Drinking Water
Disinfectant Residual – Chlorine values below reflect results from routine monthly distribution sampling at multiple sites.							
Chlorine, ppm	1.5	1.2 - 1.8	MRDL = 4	MRDLG = 4	2017	N	Water additive used to control microbes
Barium, ppm	0.04	0.02 - 0.07	2	2	2015	N	Erosion of natural deposits
Chromium, ppb	3	2 – 5	100	100	2015	N	
Fluoride, ppm	ND	ND - 0.13	2	2	2015	N	Erosion of natural deposits; water additive which promotes strong teeth
Nitrate, ppm	3.4	2.1 – 4.7	10	10	2017	N	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfection Byproducts: Compliance for Haloacetic Acids and Total Trihalomethanes is based on a running annual average of quarterly samples, not a single sample result. The range shows the highest and lowest result for individual samples.							
Haloacetic acids, ppb	26	2 - 44	60	NA	2017	N	Byproducts of drinking water chlorination
Total Trihalomethanes, ppb	38	7 - 66	80	NA	2017	N	

Violation: In September 2017, we received a monitoring violation for not collecting the correct number of bacteriological and chlorine samples. Therefore, we cannot be sure of the quality of our drinking water during that time. This monitoring violation occurred due to an administrative oversight. We have recently enhanced our sample scheduling process to prevent this type of violation from occurring again and to ensure that all required sampling is done in accordance with the state drinking water regulations.

The average concentration of radon during 2015 was 190 pCi/L. The range was ND – 580 pCi/L.

Contaminants	Entry Point #	Minimum Residual Level Required	Lowest Level Detected	Range of Detections	Sample Date	Violation Y/N	Major Sources in Drinking Water
Entry Point Disinfectant Residual – PA Ground Water Rule: This rule requires that no well station operate below specific minimum free chlorine levels for more than 4 hours.							
Chlorine, ppm	100	0.7	0.01*	0.01 – 2.7	2017	N	Water additive used to control microbes
Chlorine, ppm	101, 103, 104	0.4	0.13*	0.13 – 2.3	2017	N	
Chlorine, ppm	102	0.51	0.01	0.01 – 2.54	2017	N	
Chlorine, ppm	105	0.54	0.05*	0.05 – 2.41	2017	N	

*Disinfectant levels did not drop below minimum required level for more than 4 hours.

Lead and Copper	90th Percentile	Total Number of Samples	Samples Exceeding Action Level	Action Level	MCLG	Sample Date	Violation Y/N	Major Sources in Drinking Water
Copper, ppm	0.68	31	0	1.3	1.3	2016	N	Corrosion of household plumbing
Lead, ppb	ND	31	1	15	0	2016	N	

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Aqua is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your cold water tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The 1996 amendments to the Safe Drinking Water Act (SDWA) require that once every five years, the U.S. Environmental Protection Agency (EPA) issue a new list of no more than 30 unregulated contaminants to be monitored by public water systems (PWSs). The Unregulated Contaminant Monitoring Rule (UCMR) provides EPA and other interested parties with scientifically valid data on the occurrence of contaminants in drinking water. These data serve as a primary source of occurrence and exposure information that the agency uses to develop regulatory decisions. If a PWS monitoring for UCMR3 finds contaminants in its drinking water, it must provide the information to its customers in this annual water quality report. Below is a table of the results of our UCMR3 monitoring in 2015. All other contaminants tested during UCMR3 were Not Detected.

Unregulated Contaminants Detected During 2015			
Unregulated Contaminant	Average Detection	Range of Detections	MCL
1,1-Dichloroethane, ppb	0.021	ND – 0.17	NA
1,4-Dioxane, ppb	0.09	ND – 0.4	NA
Chlorate, ppb	178	16 - 474	NA
Chromium, ppb	0.35	0.25 – 0.50	NA
Hexavalent chromium, ppb	0.21	0.13 – 0.32	NA
Molybdenum, ppb	0.19	ND – 1.6	NA
Strontium, ppb	108	26 - 266	NA
Vanadium, ppb	0.53	ND – 1.1	NA

Notes:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements.

Fluoride: Fluoride may help prevent tooth decay if administered properly to children, but can be harmful in excess. Customers in the Uwchlan Division receive water from unfluoridated supplies. For more information about fluoride in your tap water, call Aqua at 610.645.4248. This information may be helpful to you, your pediatrician, or your dentist in determining whether fluoride supplements or treatment are appropriate.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable.

ND: Not detected.

Nitrate: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask advice from your health care provider.

pCi/L, picoCuries/Liter: A unit of concentration for radioactive contaminants.

ppb: A unit of concentration equal to one part per billion.

ppm: A unit of concentration equal to one part per million.

PWSID: Public water supply identification number.

Water sources: Ten wells at six well stations, supplemented with water from Aqua Pennsylvania Main Division which comes from predominantly from Pickering and Perkiomen Creek and the Schuylkill River.

Municipalities: Uwchlan, Upper Uwchlan, Caln Townships.

Our water systems are designed and operated to deliver water to our customers' plumbing systems that complies with state and federal drinking water standards. This water is disinfected using chlorine, but it is not necessarily sterile. Customers' plumbing, including treatment devices, might remove, introduce or increase contaminants in tap water. All customers, and in particular operators of facilities like hotels and institutions serving susceptible populations (like hospitals and nursing homes), should properly operate and maintain the plumbing systems in these facilities. You can obtain additional information from the EPA's Safe Drinking Water Hotline at 800.426.4791.